

Drinking Water Quality Results

Parameter	Units	MCL	January 2018	February 2018	March 2018	April 2018	May 2018	June 2018	July 2018	August 2018	Sept 2018	Oct 2017	Nov 2017	Dec 2017	YTD Average	YTD Min	YTD Max
Total Coliform (P/A)	100 ml		Absent														
*Total Chlorine Residual	mg/L	4	2.32												2.32		
TTHM Sample Site Mariners	ppb	80										5.31			LRAA= 14		
HAA5 Sample Site Mariners	ppb	60										1.24			LRAA= 13		
TTHM Sample Site Anchorage	ppb	80										5.21			LRAA= 10		
HAA5 Sample Site Anchorage	ppb	60										1.18			LRAA = 7		
Copper (2016)	ppm	1.3													0.072		
Lead (2016)	ppb	15													4.400		

Abbreviations:

P/A = Present / Absent

*Total Chlorine Residual = Inhouse testing

TTHM = Total Trihalomethane

HAA5 = Haloacetic Acid

LRAA = Running annual average at each location

Compliance is based upon the running annual average at each location (LRAA).

While a sample result can exceed the MCL, the LRAA may be below the MCL and be in compliance.

Lead & Copper testing - State Regulates sampling every 3 years. Next sampling period is 2019.

mg/L = Milligrams per liter

ppm = Parts per million

ppb = Parts per billion

MCL = Maximum Contaminant Level