

## Drinking Water Quality Results

Parameter	Units	MCL	January	February	March	April	May	June	July	August	Sept	Oct	Nov	Dec	YTD	YTD	YTD
			2018	2018	2018	2018	2018	2018	2018	2018	2018	2018	2018	2017	2017	Average	Min
Total Coliform (P/A)	100 ml		Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent	Absent					
*Total Chlorine Residual	mg/L	4	2.32	2.12	2.08	2.44	2.49	2.17	2.13	2.23	1.97	2.15			2.21		
Total Trihalomethane	ppb	80	12.24			11.1			11.36			**			LRAA= 11		
Haloacetic Acid	ppb	60	3.11			1.26			8.14			**			LRAA= 5		
Copper (2016)	ppm	1.3													0.072		
Lead (2016)	ppb	15													4.400		
Fluoride (2015)	ppm	4													0.71	0.67	0.71
Sodium (2015)	ppm	N/A													110	80	110

### Abbreviations:

P/A = Present / Absent

\*Total Chlorine Residual = Inhouse testing

LRAA = Running annual average at each location

Compliance is based upon the running annual average at each location (LRAA).

While a sample result can exceed the MCL, the LRAA may be below the MCL and be in compliance.

Lead & Copper testing - State Regulates sampling every 3 years. Next sampling period is 2019.

mg/L = Milligrams per liter

ppm = Parts per million

ppb = Parts per billion

MCL = Maximum Contaminant Level (Per Federal & State Standards)

\*\* Waiting on State for results

N/A = Not Applicable